MAJORCOM SA
56 chemin de la Flambère, 31300 TOULOUSE
France





② CEILING PLAN
1" = 1'-0"




③ SOUTH
1" = 1'-0"

Speaker Schedule-Majorcom

| Count | Manufacturer | Description | Model | Ip rating | Weight | Part number | Frequency Range |
|---|---|---|---|---|---|---|---|
| 1 | MAJORCOM | 2 Way Ceiling 15 W | P 515T VA | IP 21C | 1,73 Kg | | 100 - 22.800 Hz |
| 1 | MAJORCOM | 2 Way Ceiling 15 W | P 515T VA | IP 21C | 1,73 Kg | | 100 - 22.800 Hz |
| 1 | MAJORCOM | 2 Way Ceiling 15 W | P 515T VA | IP 21C | 1,73 Kg | | 100 - 22.800 Hz |
| 1 | MAJORCOM | 2 Way Ceiling 15 W | P 515T VA | IP 21C | 1,73 Kg | | 100 - 22.800 Hz |
| 1 | MAJORCOM | 2 Way Ceiling 15 W | P 515T VA | IP 21C | 1,73 Kg | | 100 - 22.800 Hz |
| 1 | MAJORCOM | 2 Way Ceiling 15 W | P 515T VA | IP 21C | 1,73 Kg | | 100 - 22.800 Hz |
| 1 | MAJORCOM | 2 Way Ceiling 15 W | P 515T VA | IP 21C | 1,73 Kg | | 100 - 22.800 Hz |
| 1 | MAJORCOM | 2 Way Ceiling 15 W | P 515T VA | IP 21C | 1,73 Kg | | 100 - 22.800 Hz |

EN 54 24 CE

This is a high-quality loudspeaker certified for EN54 voice alarm systems for fire detection and fire alarm systems for buildings.

CE marking according to the Construction Products Regulation EU N° 305/2011.

The performed type testing, the initial inspection of the manufacturing plant and the factory production control with continuous surveillance assessment and approval of the factory production control is done by a notified body.